

AWTA TEXTILE TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Textile Testing
A.B.N. 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O. Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

CLIENT : WHITECLIFFE IMPORTS
PO BOX 578
GLEBE NSW 2037

TEST NUMBER : 7-539084-AN
DATE : 29/08/2005

SAMPLE DESCRIPTION Clients Ref: EGE Highline Express Loop 660
Level loop pile tufted carpet
Colour: Pink/orange
Approximate pile height: 4mm

Material Specification:
Nominal composition: 100% polyamide
Nominal total pile mass: 660g/m²
Nominal backing: woven textile - synthetic

ASISO 9239.1-2003
Part 1

Reaction to Fire Tests for Floorings
Determination of the Burning Behaviour
using a Radiant Heat Source

Date of sample arrival: 16.08.2005
Date tested: 25.08.2005
Results:

CHF (Critical Heat Flux / Critical Radiant Flux)

	1	2	3	Mean	
Length	10.8	10.5	9.3	10.2	kW/m ²
Width	11	-	-	-	kW/m ²

Smoke Value

Length	20	64	82	55	% min
Width	37	-	-	-	% min

146710

2

(CONTINUED NEXT PAGE)

PAGE 1

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



This Laboratory was accredited by the National Association of Testing Authorities, Australia, for:
Chemical Testing of Textiles & Related Products
Mechanical Testing of Textiles & Related Products
Heat & Temperature Measurement

Accreditation No. 583
Accreditation No. 385
Accreditation No. 1356

The tests reported herein have been performed in accordance with its terms of accreditation. Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Textile Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved in advance by the Managing Director of AWTA Ltd.

