

TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p. (TEXTILE TESTING INSTITUTE)

Notified body No. 1021 Václavská 6, 658 41 Brno, Czech Republic

issues

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1021 - CPR - 014-1/16

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Textile floor coverings: Product group 3B - WO/PA-AB

Material: 80% wool/ 20% polyamide

Primary backing: polyester

Secondary backing: felt – acoustic back Technology: tufted – cut pile

Products placed on the market under the name or trade mark of:

Manufacturer: Egetæpper A/S

Industrivej Nord 25, DK-7400 Herning, Denmark

ID: CVR 38454218

Manufacture 1) Egetæpper A/S - Industrivej Nord 25, DK-7400 Herning, Denmark

location: 2) Egetæpper A/S - Industrivej 3, DK-6510 Gram, Denmark

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 14041:2004/ AC:2006 Resilient, textile and laminate floor coverings – Essential characteristics

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

Products fulfil the essential characteristic of reaction to fire: Class $B_{\rm fl}-s1$

The present certificate was issued on the basis of the protocol No. 1021/16/033 from 22.02.2016 issued by NB 1021 TZÚ Brno. Detailed description of product group is stated in Annex No. 1 of the certificate.

This certificate was first issued on February 22, 2016 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Brno, 22.02.2016



RNDr. Pavel Malčík Managing Director

SCOPE:

Group 3B - WO/PA-AB (80% Wool/ 20% Polyamide / Felt - Acoustic Back)

Group 3.1 (WO/PA-AB)		Tufted	Cut Pile				
Class $B_{fl} - s1$							
Total weight	3 100 – 3 600 g.m ⁻²	Total thickness	11 – 12,5 mm				
Pile weight	1 400 – 1 900 g.m ⁻²	Pile thickness	6,5 – 9 mm				
Classification report	VNLF 082013.2 (8.2.2016)	Classification	EN 13501-1 + A1				
Products in group	Highline 80/20 1400 AB	Highline 80/20 1900 AB					
	Highline 80/20 1600 AB						

Field of application	Horizontal laid floor coverings in form of rolls. The carpet is to be mounted			
	on a substrate of Euroclass A1 _{fl} or A2 _{fl} with a density of at least 1350 kg.m ⁻³ .			
	It is declared for installation with a polyacrylat - copolymer dispersion			
	adhesive (Ege 90RH) or similar.			

TEST REPORTS and DOCUMENTATION:

Product	Test report	Date	Accredited	Product
			laboratory	documentation
Highline 80/20 1400 AB	PF12442n	17.10.2006	DBI	4.2.2016
Highline 80/20 1600 AB	PF13281b	8.3.2010	DBI	
Highline 80/20 1900 AB	PFA10682	2.3.2015	DBI	

